



OFFICE OF THE DEPUTY FIRE OFFICER,
ANGUL CIRCLE, ANGUL, PIN-759122

Tel.No: 06764- 232444, Mob No: 7655072548 (CUG) Email ID: dfoang-ofs@gov.in

FORM- V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of Odisha Fire Prevention and Fire Safety Rules-2017)

File No. A-01-2019

Certificate No.67/2021 of Angul Circle

Date: 09.09.2021.

This Initial Certificate is valid up to 08.09.2023.

(Apply for renewal at least three months before expiry)


Certified that, DAV Public School, MCL, Jagannath Area situated over Plot No.252/497, Khata No.7, Mouza- Ghantapada, Talcher, Dist- Angul was inspected by a team of Officers of Odisha Fire Service on 09.09.2021 in presence of Mrs Sukla Chakraborty, Principal and it has been found to comply with the Fire Prevention and Safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules-2017 and that its various floors are fit for occupancy or usage as noted here under against each subject to compliance to the conditions as prescribed herein below.

G+1----- Educational Building (DAV Public School)

CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access there to etc provided in the building or premises, should be maintained by the occupier in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers shall train all staff and occupants periodically to make them well conversant in use and operation of Fire Prevention and safety measures.
4. Fire drills/Rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Tower/Blocks of building/premises.

By order of the Director of Fire Service



(Simanchala Padhi)
Deputy Fire Officer
Angul Circle, Angul
Simanchala Padhi
Deputy Fire Officer
Angul Circle, Angul

Contd.....Page-2

Memo No.1351/AGL Circle

Date: 09.09.2021.

Copy to Mrs Sukla Chakraborty, Principal, DAV Public School, MCL, Jagannath Area, PO-Dera, Talcher, Dist- Angul, Odisha, PIN-759103 for information and necessary action.



(Simanchala Padhi)
Deputy Fire Officer
Angul Circle, Angul
Simanchala Padhi
Deputy Fire Officer
Angul Circle, Angul

Memo No.1352_/AGL Circle

Date: 09.09.2021.

Copy to Station Officer, Talcher Fire Station for information.




(Simanchala Padhi)
Deputy Fire Officer
Angul Circle, Angul


Memo No.1353 (2)/AGL Circle

Date:09.09.2021.

Copy submitted to Chief Fire Officer (FPW), Directorate of Fire Services, Odisha, Cuttack/Fire Officer, NR, Sambalpur for favour of kind information.



(Simanchala Padhi)
Deputy Fire Officer
Angul Circle, Angul



Principal
D.A.V.Public School
MCL Jagannath Area, Talcher